



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
BUREAU OF FIRE SERVICES
RICHARD W. MILLER
STATE FIRE MARSHAL

MIKE ZIMMER
DIRECTOR

Frequently Asked Questions Storage Tank New Rule Requirements

1. **Question: Can I have tanks on site which must comply with different rules or will all of my tanks be regulated the same?**

Answer: Yes, based on the Department of Attorney General's opinion, if the tanks are in compliance with the Rules at the time of their installation or are in compliance with the current Rules, they will be considered to be in compliance. You may have different rules for different tanks on the same site.

2. **Question: If I have a device (piece of equipment) which is no longer required and it fails but it does not affect the function of the system, can I leave it in place or do I need to remove it?**

Answer: As long as the device (piece of equipment) is not required and does not impact the regulatory requirements of the system, it is not required to be removed.

3. **Question: How will the inspectors know which Rules my tanks are required to meet? How do I know?**

Answer: Based on the Department of Attorney General's opinion, if the tanks are in compliance with the rules at the time of their installation or are in compliance with the current rules, they will be considered to be in compliance. You can have different rules for different tanks on the same site depending on year of installation.

4. **Question: What is the distance requirement for Aboveground Storage Tank (AST) and Underground Storage Tank (UST) from property lines and/or buildings?**

Answer: Based on the use and size of the tank will determine setbacks for all AST's, which can be found in the Flammable/Combustible Liquid (FL/CL) Rules. The setbacks for all new UST's is 10 feet to any structure and 3 feet to a property line for a Class I liquid and 1 foot to a property line for a Class II or higher liquid.

5. **Question: What are the AST size limits for bulk tanks?**

Answer: Unlimited for single wall tanks in approved secondary containment, 12,000 gallons for double wall tanks unless Class II or higher, then 20,000 gallons.

LARA is an equal opportunity employer

Auxiliary aids, services and other reasonable accommodations are available upon request to individuals with disabilities.

3101 TECHNOLOGY BLVD., SUITE H • P.O. BOX 30700 • LANSING, MICHIGAN 48909

www.michigan.gov/bfs • (517) 241-8847 • Fax: (517) 332-1427 or (517) 332-1428

6. Question: What are the AST size limits for Motor Vehicle Fueling?

Answer: 12,000 gallons for any retail and any Class I. 20,000 gallons for Class II used for Fleet (private) fueling.

7. Question: What are the new size limits for UL2085 tanks?

Answer: For bulk tanks unlimited for single wall tanks in approved secondary containment, 12,000 gallons for double wall tanks unless Class II or higher, then 20,000 gallons. For motor vehicle fueling tanks 12,000 gallons for any retail and any Class I. 20,000 gallons for Class II used for Fleet (private) fueling.

8. Question: What are the dispenser distances- new vs. old rules?

Answer: According to the FL/CL Rules, as amended, Section 4.3.2.6 of Part 3 of the FL/CL Rules and Table 4.3.2.4 of the same.

9. Question: What are the new signage requirements at the pumps?

Answer: For new installations or replacements of signs at an existing location, **see Section 9.2.5.4 of Part 3 of the FL/CL Rules** for what signs are required now at the dispenser.

10. Question: Is Liquefied Petroleum Gas (LPG) signage- no longer required?

Answer: That is correct.

11. Question: Are weekly/monthly dispenser inspections required?

Answer: For all installations after October 13, 2014, these are required.

11. Question: Are release reporting requirements for heating oil UST's no longer required?

Answer: They are not required to the Storage Tank Division, however all Part 201 requirements remain.

12. Question: What are the requirements for a Fire safety analysis for LPG tanks over 4,000 gal?

Answer: See Section 6.27 of the LPG Rules.

13. Question: Have AST distances from churches, schools, etc. changed?

Answer: Previous requirements have been rescinded. Setbacks are now the same for all buildings as listed in the adopted National Fire Protection Association pamphlets.

14. Question: The old rules required pac-pride users to have preset gallon limits and the new rules do not. Is it only for new systems or all pac-pride systems now?

Answer: These sites are all approved under a variance request; please see the approval letters for each site to determine the requirements for each site.

For more information pertaining to storage and Handling of Flammable and Combustible Liquids, you may visit the [Storage Tank Division webpage](#) or you may call 517-241-8847.